



# tellus point xmp

tunableWhite



USER MANUAL



BEDIENUNGSANLEITUNG

## USER MANUAL

# tellus point xmp

tunableWhite

## Safety Instructions



**Devices must be installed by qualified personnel in compliance with all pertaining regulations.**


- Always refer to the technical parameters in the data sheet. All items are subject to technical modification.
- Refer to the attached User Manual as a basis for correct use.
- Consult circuit diagram for correct wiring.
- Note! Before attempting any work, make sure device is separated from main power. Protect device from moisture.
- Make sure protection against line voltage shock is provided during installation.
- We recommend securing the installation by RCD circuit breakers.
- Note that adjacent parts or devices must be temperature proof up to 90°C.
- Do not operate the fixture with inductive consumers (fluorescent lamps, gas discharge lamps, ventilators etc.) in the same electric circuit. Activation of inductive consumers can cause damage to the operating device.
- Do not place heat insulation material on the fixture.
- Mind the operating temperatures of the fixture according to the technical data sheet.
- Before drilling the mounting holes, take precautions not to harm or damage any power lines.
- Do not solder cable strands. Use cable strand sleeves instead.
- Note and mind voltage label on the device.
- Make sure flawless electrical connectivity is provided.
- Connecting the lamp to the powered-up device can cause damage to the lamp! (voids product warranty!)
- No modification allowed. No liability will be assumed in case of damage incurred by alteration, improper use or faulty installation.

### **Important Information for the installation of the in-ground luminaire tellus m:**

- The luminaire may not be used in areas where it may be exposed to horizontal forces. Horizontal forces occur for example when braking, accelerating or any change of direction.
- The luminaire incl. The installation housing has to be installed flush.
- The luminaire, taking into account the maximum specified pressure load (assuming appropriate foundation), can be rolled over of vehicles with pneumatic tires

## Scope of delivery

- Check completeness of supplied device immediately after receipt.



In delivery included:

- 1x User Manual
- 1x Luminaire Bion Technologies tellus xs
- 2x Lighting Connector (cETLus delivery only)


If you detect any transportation damage or differences between specified packing contents and your unpacked delivery, please contact your dealer immediately.

## Technical Data

Dimensions	110 mm x 110 mm [W x H] 4.33 in x 4.33 in [W x H]
Standard Unit Lengths	110 mm (XS), 220 mm (S), 268 mm (M) 4.34 in (XS), 8.67 in (S), 10.56 in (M)
Fixture Typ	 tunableWhite
Color Temperatures tunableWhite	3000 K - 6000 K
Beam Angles	8°, 10°, 23°, 43°, 52° 8° x 31°, 10° x 42°, 12° x 60°, 14° x 100°, 30° x 58° (Tilt in C0-plane: -14°), 30° x 11° (Tilt in C0-plane: -14°), 110°
Luminous Flux	110 mm (4.34 in): 550 lm 220 mm (8.67 in): 1100 lm 268 mm (10.56 in): 1650 lm Without glare protection
Light Source	110 mm (4.34 in): 4 LEDs 220 mm (8.67 in): 8 LEDs 268 mm (10.56 in): 12 LEDs
Antiglare	Honeycomb, linear louver
LED-Binning	
MacAdam Ellipses Binning	3
Control	DMX, DALI, IOT

Input Voltage	Power supply: internal   100 - 240, 277 VAC (50 - 60 Hz)   127 - 431 VDC * XS -> 100 - 240 VAC (50 - 60 Hz)   127 - 370 VDC
Power Consumption	110 mm (4.34 in): Max. 7 W 220 mm (8.67 in): Max. 14 W 268 mm (10.56 in): Max. 21 W
Protection Class	I
Inrush	Cold Start 70A@230VAC / 34A@110VAC (tDauer=120µs gemessen an 50% Ipeak)
Storage Temperatur	-40 °C / +80 °C   -40 °F / +176 °F
Operating Temperature	-40 °C / +40 °C   -40 °F / +104 °F
Start-up Temperature	-25 °C / +40 °C   -13 °F / +104 °F
Lumen Maintenance [L70]	65'000 h @ 25 °C (77 °F)   40'000 h @ 40 °C (104 °F)
LED-Class	Class 2 LED product
Housing	Extruded aluminium profile
Housing Color(s)	Black anodized
Lens	Tempered safety glass
Frame	Stainless steel
Weight	1,3 kg (2.9 lbs)
Load	500 kg   1100 lbs
Ingress Protection	IP67
Environment	 indoor  outdoor
Impact Protection	IK09
Certification	  

# Engineering Drawing




## Load Table

### Load Table 230 V

230 V	B10	B16	C10	C16
110 mm (4.34 in)	-	17	-	29
220 mm (8.67 in)	-	-	-	-
268 mm (10.56 in)	-	-	-	-

# Mounting

## 1. Installation




### Foundation

The customer should provide a proper foundation to achieve the maximum pressure load. The luminaire is mounted in a recess housing made of high-strength stainless steel (The installation housing to be ordered separately). The pressure load is transferred to the foundation by this housing. The foundation must be carried out on a firm subgrade. In order to obtain a firm stability, the recess housing has to be firmly concreted in. During the preparation of the foundation, proper drainage shall be provided, so that entering surface water can drain off.


### Soil condition

The luminaire should not have permanent contact with aggressive media. Aggressive media might be washed out of the soil and corrode the luminaire housing. In case of unknown soil composition, a soil analysis should be made before installation. Aggressive media that is outgoing from the ground surface might also affect the luminaire. Thus an overuse of deicing agents in the surroundings should be avoided. Parasitic current, occurring from outside, which is conducted by the luminaire into the soil, will cause corrosion damage. Suitable countermeasures have to be carried out.

## 2. Drainage system



### 3. Mounting




The luminaire must only be operated with the complete protective cover. The support for the housing must be load-bearing for the final use.

It's important to ensure the drainage system described the point before.

# Commissioning


## 1. Wiring / DMX Wiring - CE



The luminaire connection must be made outside the recess housing by means of a connection sleeve supplied by others. Connect lead mains supply cable with mains supply cable tightly. 0.3 meters of cable must be left in the recess housing for lifting out the luminaire. Strain relief the cable connection. Install the cable only in suitable tubes not directly in the ground. Insert the luminaire housing into the recess housing. Tighten locking screws firmly.

Please remove the label on surface before operating the fixture.


## 2. Wiring / DMX Wiring - North America (110 V)



The luminaire connection must be made outside the recess housing by means of a connection sleeve supplied by others. Connect lead mains supply cable with mains supply cable tightly. 0.3 meters of cable must be left in the recess housing for lifting out the luminaire. Strain relief the cable connection. Install the cable only in suitable tubes not directly in the ground. Insert the luminaire housing into the recess housing. Tighten locking screws firmly.

Please remove the label on surface before operating the fixture.


### 3. Wiring / 0-10v Wiring - CE



The luminaire connection must be made outside the recess housing by means of a connection sleeve supplied by others. Connect lead mains supply cable with mains supply cable tightly. 0.3 meters of cable must be left in the recess housing for lifting out the luminaire. Strain relief the cable connection. Install the cable only in suitable tubes not directly in the ground. Insert the luminaire housing into the recess housing. Tighten locking screws firmly.

Please remove the label on surface before operating the fixture.

#### 4. Wiring / 0-10v Wiring - North America (110 V)



The luminaire connection must be made outside the recess housing by means of a connection sleeve supplied by others. Connect lead mains supply cable with mains supply cable tightly. 0.3 meters of cable must be left in the recess housing for lifting out the luminaire. Strain relief the cable connection. Install the cable only in suitable tubes not directly in the ground. Insert the luminaire housing into the recess housing. Tighten locking screws firmly.

Please remove the label on surface before operating the fixture.

## Maintenance

Clean device from dirt and residue regularly. Use solvent-free cleaning agents only and do not employ aggressive chemicals or high pressure cleaner. Operate device only after complete drying.

## Conformity



Our devices are certified according to the following European and American Standards:

### NOTE

This equipment has been tested and found to comply with the limits for a class a digital device, pursuant to part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of these equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

„This Class (B) digital apparatus complies with Canadian ICES-003”

## Manufacturer



### Bion Technologies GmbH

Lindberghstrasse 15  
86343 Koenigsbrunn  
Tel: +49 (0)8231/95787-0  
Fax: +49 (0)8231/95787-29  
[www.biontechnologies.com](http://www.biontechnologies.com)  
[info@biontechnologies.com](mailto:info@biontechnologies.com)

YouTube: <http://www.youtube.com/BIONTECHNOLOGIES>

All rights reserved / Subject to change / Specifications may change without notice

## BEDIENUNGSANLEITUNG

# tellus point xmp

tunableWhite

### Sicherheitshinweise



**Anschluss und Bedienung dieses Geräts sollte ausschließlich von qualifiziertem Fachpersonal in Übereinstimmung mit allen geltenden Vorschriften erfolgen.**

- Beachten Sie immer die technischen Daten auf dem Datenblatt. Technische Änderungen vorbehalten.
- Die beigegefügte Gebrauchsanleitung ist Voraussetzung für den ordnungsgemäßen Gebrauch.
- Die Aderbelegung ist gemäß Schaltschema zu beachten!
- Achtung! Vor Beginn der Arbeiten ist die Netzleitung spannungsfrei zu schalten! Gerät vor Nässe schützen.
- Der Schutz gegen elektrischen Schlag ist beim Einbau sicherzustellen. Wir empfehlen die bauseitige Absicherung über einen Fehlerstrom Schutzschalter.
- Beim Einbau ist darauf zu achten, dass benachbarte Bauteile einer Temperatur von 90°C standhalten.
- Leuchte nicht gemeinsam mit induktiven Lasten (Leuchtstofflampen, Entladungslampen, Ventilatoren usw.) im gleichen Stromkreis betreiben. Beim Schalten induktiver Lasten können Defekte an der Leuchte entstehen.
- Wärmedämmung darf nicht auf der Leuchte liegen.
- Beim Einbau ist auf die, in den technischen Daten angegebene, Betriebstemperatur zu beachten!
- Beim Bohren der Befestigungslöcher ist darauf zu achten, dass die Netzleitungen nicht beschädigt werden.
- Litzendrähte dürfen nicht verlötet werden. Es sind Aderendhülsen zu verwenden.
- Spannungskennzeichnung auf dem Betriebsgerät beachten.
- Ein einwandfreier elektrischer Übergang ist beim Anschließen der Leuchte zu gewährleisten.
- Die Leuchte darf nicht geöffnet werden. (Kein Gewährleistungsfall)
- Jegliche Veränderung ist untersagt. Der Hersteller übernimmt keine Haftung durch Schäden die durch Veränderung, unsachgemäßen Einsatz oder fehlerhafte Montage entstehen.
- Gerät trocken lagern und vor Beschädigung schützen!


#### **Wichtige Hinweise zu Einsatz der Bodeinbauleuchte tellus m:**

- Die Leuchte darf nicht in Bereichen eingesetzt werden, in denen Sie horizontalen Kräften ausgesetzt ist. Horizontale Kräfte entstehen zum Beispiel durch Bremsen, Beschleunigen oder einen Richtungswechsel.
- Die Leuchte ist inkl. Bodeneinbaugehäuse flächenbündig einzubauen.
- Die Leuchte kann von Fahrzeugen mit luftgefüllten Reifen unter Berücksichtigung der maximalen angegebenen Druckbelastung (Voraussetzung entsprechende Gründung) überrollt werden.



## Lieferumfang

- Packen Sie alle Teile aus.
- Prüfen Sie den Verpackungsinhalt auf sichtbare Transportschäden.
- Prüfen Sie, ob der Verpackungsinhalt vollständig ist.



Im Lieferumfang enthalten:

- 1x Bedienungsanleitung
- 1x Leuchte Bion Technologies tellus xs
- 2x Leuchtenklemme (nur in cETLus Ausführung)


Wenn Sie Transportschäden oder Unstimmigkeiten zwischen dem hier angegebenen Lieferumfang und Verpackungsinhalt feststellen, informieren Sie unverzüglich Ihre Verkaufsstelle.

## Technische Daten

Abmessungen	110 mm x 110 mm [B x H] 4.33 in x 4.33 in [B x H]
Leuchtenlängen	110 mm (XS), 220 mm (S), 268 mm (M) 4.34 in (XS), 8.67 in (S), 10.56 in (M)
Leuchtentyp	 tunableWhite
Farbtemperaturen tunableWhite	3000 K - 6000 K
Abstrahlwinkel	8°, 10°, 23°, 43°, 52° 8° x 31°, 10° x 42°, 12° x 60°, 14° x 100°, 30° x 58° (Tilt der C0-Ebene: -14°), 30° x 11° (Tilt der C0-Ebene: -14°), 110°
Lichtstrom	110 mm (4.34 in): 550 lm 220 mm (8.67 in): 1100 lm 268 mm (10.56 in): 1650 lm ohne Entblendung
Lichtquelle	110 mm (4.34 in): 4 LEDs 220 mm (8.67 in): 8 LEDs 268 mm (10.56 in): 12 LEDs
Entblendung	Wabenstruktur, Linearraster
LED-Binning	
MacAdam-Ellipsen Binning	3
Steuerung	DMX, DALI, IOT

Eingangsspannung	Netzteil: intern   100 - 240, 277 VAC (50 - 60 Hz)   127 - 431 VDC * XS -> 100 - 240 VAC (50 - 60 Hz)   127 - 370 VDC
Wirkleistungsaufnahme	110 mm (4.34 in): Max. 7 W 220 mm (8.67 in): Max. 14 W 268 mm (10.56 in): Max. 21 W
Schutzklasse	I
Einschaltstrom	Kaltstart 70A@230VAC / 34A@110VAC (tDauer=120µs gemessen an 50% Ipeak)
Lagertemperatur	-40 °C / +80 °C   -40 °F / +176 °F
Betriebstemperatur	-40 °C / +40 °C   -40 °F / +104 °F
Einschalttemperatur	-25 °C / +40 °C   -13 °F / +104 °F
Lebensdauer [L70]	65'000 h @ 25 °C (77 °F)   40'000 h @ 40 °C (104 °F)
LED-Klasse	Klasse 2 LED Produkt
Gehäuse	Aluminium-Strangpressprofil
Gehäusefarbe(n)	Schwarz eloxiert
Linse	Gehärtetes Sicherheitsglas
Rahmen	Edelstahl
Gewicht	1,3 kg (2.9 lbs)
Druckbelastung	500 kg   1100 lbs
Schutzart	IP67
Umgebung	 indoor  outdoor
Schlagschutz	IK09
Zulassungen	  

# Technische Zeichnung




## Lasttabelle

Lasttabelle 230 V

230 V	B10	B16	C10	C16
110 mm (4.34 in)	-	17	-	29
220 mm (8.67 in)	-	-	-	-
268 mm (10.56 in)	-	-	-	-

# Montage

## 1. Allgemeine Einbauinformationen




### Fundament

Um die maximale Druckbelastung der Leuchte aufnehmen zu können, ist die Errichtung eines Fundamentes erforderlich. Die Leuchte steht in einem Einbaugehäuse aus hochfestem Edelstahl (Das Installationsgehäuse ist separat zu bestellen). Die Druckbelastung wird über dieses Gehäuse auf das bauseits zu erstellende Fundament übertragen. Die Gründung muss auf festem Untergrund erfolgen. Um eine sichere Standfestigkeit zu erreichen, muss das Einbaugehäuse einbetoniert werden. Bei der Erstellung des Fundaments ist eine Drainage anzulegen, damit eintretendes Oberflächenwasser aus dem Einbaugehäuse abfließen kann.


### Bodenbeschaffenheit

Die Leuchte darf nicht dauerhaft mit aggressiven Medien in Kontakt kommen. Aggressive Medien können durch Wasser aus dem Boden gewaschen werden und das Gehäuse der Leuchte zerstören. Bei unbekannter Zusammensetzung des Bodens ist daher vor der Montage eine Bodenanalyse vorzunehmen. Aggressive Medien können auch von der Oberfläche ausgehend auf die Leuchte einwirken, daher ist übermäßiger Einsatz von Taumitteln im Umfeld der Leuchte zu vermeiden. Von außen eintretende Streuströme die durch die Leuchte in den Boden weitergeleitet werden, verursachen Korrosionsschäden. Es sind geeignete Gegenmaßnahmen durchzuführen.

## 2. Drainagesystem



### 3. Montage




Die Leuchte darf nur mit Ihrer vollständigen Schutzabdeckung betrieben werden. Der Untergrund muss gemäß der späteren Nutzung tragend sein.

Auf die vorhergehend beschriebene Drainage ist zu achten.

# Inbetriebnahme


## 1. Verkabelung / DMX Verdrahtung - CE



Der Leuchtenanschluss erfolgt über eine bauseitige Verbindungsmuffe außerhalb des Einbaugeschäuses. Anschlussleitung mit Erdkabel dicht verbinden. Für das Herausnehmen der Leuchte ist im Einbaugeschäuser eine Leitungslänge von 0,3 m vorzusehen. Leitungen nur geschützt (z.B.: geeignete Installationsrohre) im Erdreich verlegen. Leuchtengeschäuser in das Einbaugeschäuser setzen. Verschluss Schrauben festziehen.

Vor Inbetriebnahme der Leuchte entfernen Sie bitte den Hinweis-Aufkleber auf der Leuchtenoberfläche.


## 2. Verkabelung / DMX Verdrahtung - Nord Amerika (110 V)



Der Leuchtenanschluss erfolgt über eine bauseitige Verbindungsmuffe außerhalb des Einbaugeschäuses. Anschlussleitung mit Erdkabel dicht verbinden. Für das Herausnehmen der Leuchte ist im Einbaugeschäuser eine Leitungslänge von 0,3 m vorzusehen. Leitungen nur geschützt (z.B.: geeignete Installationsrohre) im Erdreich verlegen. Leuchtengeschäuser in das Einbaugeschäuser setzen. Verschluss Schrauben festziehen.

Vor Inbetriebnahme der Leuchte entfernen Sie bitte den Hinweis-Aufkleber auf der Leuchtenoberfläche.


### 3. Verkabelung / 0-10v Verdrahtung - CE



Der Leuchtenanschluss erfolgt über eine bauseitige Verbindungsmuffe außerhalb des Einbaugeschüsses. Anschlussleitung mit Erdkabel dicht verbinden. Für das Herausnehmen der Leuchte ist im Einbaugeschüss eine Leitungslänge von 0,3 m vorzusehen. Leitungen nur geschützt (z.B.: geeignete Installationsrohre) im Erdreich verlegen. Leuchtengeschüss in das Einbaugeschüss setzen. Verschluss Schrauben festziehen.

Vor Inbetriebnahme der Leuchte entfernen Sie bitte den Hinweis-Aufkleber auf der Leuchtenoberfläche.

#### 4. Verkabelung / 0-10v Verdrahtung - Nord Amerika (110 V)



Der Leuchtenanschluss erfolgt über eine bauseitige Verbindungsmuffe außerhalb des Einbaugeschützes. Anschlussleitung mit Erdkabel dicht verbinden. Für das Herausnehmen der Leuchte ist im Einbaugeschütz eine Leitungslänge von 0,3 m vorzusehen. Leitungen nur geschützt (z.B.: geeignete Installationsrohre) im Erdreich verlegen. Leuchtengeschütz in das Einbaugeschütz setzen. Verschluss Schrauben festziehen.

Vor Inbetriebnahme der Leuchte entfernen Sie bitte den Hinweis-Aufkleber auf der Leuchtenoberfläche.

## Wartung + Pflege

Gerät regelmäßig mit einem feuchten Tuch reinigen. Verwenden Sie ausschließlich lösungsmittelfreie Reinigungsmittel und verwenden Sie keine Chemikalien.

## Konformität



Unsere Geräte sind nachfolgend nach den Europäischen und Amerikanischen Standards zertifiziert.

### HINWEIS

Dieses Gerät wurde getestet und entspricht den Grenzwerten für digitale Geräte der Klasse B gemäß Teil 15 der FCC-Regeln. Diese Grenzwerte sollen einen angemessenen Schutz vor schädlichen Störungen bieten, wenn das Gerät kommerziell betrieben wird. Dieses Gerät erzeugt Hochfrequenzenergie und kann bei unsachgemäßer oder abweichender Installation gemäß der mitgelieferten Bedienungsanleitung zu Störungen des Funkverkehrs führen. Bei Betrieb dieser Geräte in einer Wohngegend besteht die Möglichkeit das Störungen entstehen. In diesem Fall ist der Benutzer verpflichtet, die Störung auf eigene Kosten zu beheben.

„Diese Klasse (B) für digitale Geräte entspricht der kanadischen ICES-003“

## Hersteller



### Bion Technologies GmbH

Lindberghstrasse 15  
86343 Koenigsbrunn  
Tel: +49 (0)8231/95787-0  
Fax: +49 (0)8231/95787-29  
[www.biontechnologies.com](http://www.biontechnologies.com)  
[info@biontechnologies.com](mailto:info@biontechnologies.com)

YouTube: <http://www.youtube.com/BIONTECHNOLOGIES>

All rights reserved / Subject to change / Specifications may change without notice



Lindberghstrasse 15  
86343 Koenigsbrunn  
Tel: +49 (0)8231/95787-0  
Fax: +49 (0)8231/95787-29  
[www.biontechnologies.com](http://www.biontechnologies.com)  
[info@biontechnologies.com](mailto:info@biontechnologies.com)

YouTube: <http://www.youtube.com/user/BIONTECHNOLOGIES>

© 2022, BION TECHNOLOGIS GMBH  
All rights reserved / Subject to change / Specifications may change without notice